



“SAFETY RANKING OF DISCOS & TCN IN THE POWER SECTOR” OCTOBER 2018 RANKING

by

Engr. Peter .O. Ewesor
*Managing Director/CEO &
Chief Electrical Inspector of the Federation*

NEMSA

Many of the accidents that occur in the power industry can be attributed to these major factors:

(i) System Protection Equipment Failures;

(ii) In some cases, total absence of protection devices.

(iii) Poor Terminations, poor maintenance of Ageing Networks, Right-of-way issues.

(iv) Poor Response to Monitored Networks & use of substandard materials.

(v) Non adherence to safety rules, and regulations .

(vi) Inadequate knowledge and Ignorance on the part of operators/consumers/public.

(vii) Vandalism

Operators of the Power Sector to address these urgently.



RANKING CRITERIA

DESCRIPTION	EVENT	SCORES
I. TOTAL ACCIDENTS	NOT SCORED	NOT SCORED
II. NO. OF FATALITIES	0	40
III. NO. OF MAJOR INJURIES	0	25
IV. NO. OF BAD NETWORKS RESOLVED	>9	25
V. REPORTING COMPLIANCE	4	10
		100

Fatalities (Deaths)	
No. of Fatalities	Scores
0	40
1 - 2	32
3 - 4	24
5 - 6	16
7 - 8	8
9 & Above	0

Major Injuries	
No. of Persons with Major Injuries	Scores
0	25
1 - 2	20
3 - 4	15
5 - 6	10
7 - 8	5
9 & Above	0

NETWORK RESOLVED	
No. Resolved	Scores
9 & Above	25
7 - 8	20
5 - 6	15
3 - 4	10
1 - 2	5
0	0

Response	Scores
4	10
3	8
2	6
1	4
0	0

2015 BASELINE STUDY:
Average Deaths/ month = 9.5 (10)

2015 BASELINE STUDY:
Not Available

2015 BASELINE STUDY:
Average/ month = 7.5 (8)

Criterion for Network Monitored/Resolved to be revised upwards



NIGERIAN ELECTRICITY MANAGEMENT SERVICES AGENCY (NEMSA)



RAW DATA


MONTH: OCTOBER 2018

WEIGHTED SCORE

S/No.	DISCO	TOTAL ACCIDENTS WITH DEATHS	TOTAL NO. OF DEATHS [STAFF & 3RD PARTY]	NO. OF MAJOR INJURIES	NO. OF BAD NETWORKS RESOLVED BY DISCO / TCN	REPORTING COMPLIANCE
1	ABUJA	4	4	0	14	4
2	BENIN	0	0	0	6	4
3	EKO	2	2	1	15	4
4	ENUGU	0	0	0	45	4
5	IBADAN	0	0	0	11	4
6	IKEJA	2	2	0	20	4
7	JOS	0	0	0	13	4
8	KADUNA	0	0	0	40	4
9	KANO	2	2	0	19	4
10	PORT HARCOURT	1	1	0	1	4
11	YOLA	0	0	0	9	4
12	TCN	1	1	2	0	4
TOTAL		12	12	3	193	

DEATHS [STAFF & 3RD PARTY]	MAJOR INJURIES	BAD NETWORKS RESOLVED	REPORTING COMPLIANCE	TOTAL	RANKING
24	25	25	10	84	5
40	25	15	10	90	3
32	20	25	10	87	4
40	25	25	10	100	1
40	25	25	10	100	1
32	25	25	10	92	2
40	25	25	10	100	1
40	25	25	10	100	1
32	25	25	10	92	2
32	25	25	10	92	2
40	25	25	10	100	1
32	20	0	10	62	6

Note: Discos should rectify defective networks reported to them by NEMSA as a priority. Notification by Discos to NEMSA for verification should be weekly, rather than waiting till end of the month.



NIGERIAN ELECTRICITY MANAGEMENT SERVICES AGENCY (NEMSA)



Compliance Record on Disconnection of Structures/Premises under or within Right-of-Way of Power Lines

S/No.	DISCO	TOTAL PREMISES/STRUCTURES DISCONNECTED	TOTAL PREMISES/STRUCTURES DEMOLISHED	RANKING
1	ABUJA	0	0	LAST
2	BENIN	52	0	1
3	EKO	0	0	LAST
4	ENUGU	0	0	LAST
5	IBADAN	36	0	2
6	IKEJA	0	0	LAST
7	JOS	13	0	3
8	KADUNA	0	0	LAST
9	KANO	0	0	LAST
10	PORT HARCOURT	0	0	LAST
11	YOLA	0	0	LAST
TOTAL		101	0	

Notes:

1. Compliance by Discos to disconnect premises/buildings/structures under and within right-of-way of power lines has been unsatisfactory.
2. Discos are to note that they will be liable should electrical accidents occur in premises/buildings/structures which are under and/or within right-of-way of power lines and which the Discos are supplying electricity to.



Cumulative Disconnection of Structures/Premises under or within Right-of-Way of Power Lines as at October 2018



S/No.	DISCO	Disconnected in the month	Cumulative YTD Premises/ Structures reported disconnected by Discos
1	ABUJA	0	0
2	BENIN	52	126
3	EKO	0	0
4	ENUGU	0	0
5	IBADAN	36	643
6	IKEJA	0	100
7	JOS	13	112
8	KADUNA	0	11
9	KANO	0	2
10	PORT HARCOURT	0	352
11	YOLA	0	0
	TOTAL	101	1346



NIGERIAN ELECTRICITY MANAGEMENT SERVICES AGENCY (NEMSA)



DISCOS & TCN RANKING TREND IN 2018

S/N o.	DISCO	JAN	FEB	MARCH	APRIL	MAY	JUNE	JULY	AUG	SEPT	OCT	NOV	DEC	YTD
1	ABUJA	1	4	2	8	5	6	1	1	4	5			7
2	BENIN	5	3	3	1	1	1	3	1	6	3			4
3	EKO	1	1	3	6	7	5	1	3	2	4			6
4	ENUGU	1	3	1	5	1	1	3	1	1	1			1
5	IBADAN	8	2	1	7	3	1	1	1	2	1			4
6	IKEJA	2	4	1	2	2	4	2	3	1	2			3
7	JOS	6	1	3	5	8	5	4	5	2	1			8
8	KADUNA	1	1	6	3	2	1	1	1	1	1			1
9	KANO	3	1	4	4	2	2	3	6	2	2			5
10	PORT HARCOURT	4	2	1	1	1	3	1	2	3	2			2
11	YOLA	1	3	1	3	4	1	1	1	2	1			1
12	TCN	7	5	5	6	6	4	5	4	5	6			9

Operators of the Power Sector to note: Zero target for Electrocutions nationwide.

Discos are encouraged to report domestic electrocutions not directly connected with their networks, for information only. This will not count against their ranking.

Discos to intensify efforts at:

- (i) revamping/calibrating their protection schemes & equipment***
- (ii) rectifying defective networks to prevent electrical accidents and reduce technical losses.***
- [iii] educating the general public on the need for extreme caution with using electricity!***



SAFETY TIPS

- **Do not build structures or carry out activities under power lines**
- **Avoid contact with electric poles, Tv antenna poles, conductors and other electrical equipment installed in the open.**
- **Avoid staying under trees with conductors running over such trees.**
- **Avoid climbing masts constructed close to power lines.**
- **Avoid power cables and metallic objects.**
- **Wear rubber sole shoes always when on wet grounds.**
- **Report any fallen electric poles or conductors to the nearest electricity utility company or to NEMSA office nearest to you. Do not attempt to touch these.**

***Work Safely!
Safety First - Safety Always
- NEMSA.***

***Thank
You!***